



## VILLAGE OF WEST MILWAUKEE

Village Hall  
4755 WEST BELOIT ROAD  
WEST MILWAUKEE, WI 53214  
TELEPHONE (414) 645-1530  
FAX (414) 671-8089  
www.westmilwaukee.org

### RIGHT OF WAY AND

### PAVEMENT RESTORATION GUIDELINES

DPW 4517 W. Burnham Street, West Milwaukee WI 53214 Ph 414-645-6238 Fax 414-671-8089

The following special provisions must be included with any Special Permit that a utility company or contractor is applying for that requires excavating and/or disturbances to surface improvements in the Village of West Milwaukee's public right of ways.

- 1¼" epoxy coated, smooth dowel bars 18" long 2' on center along transverse joints and ½" or larger deformed bars epoxy coated 18" long 2' on center along longitudinal joints.
- All pavement must be saw cut full depth and no over cuts are allowed unless in an existing joint.
- 6' minimum trench width & joint to joint replacement unless specified by Superintendent Public Works.
- Back fill must be Crushed Limestone (¾" dense graded base material) with mechanical compaction or Aggregate Slurry material.
- Trench must be inspected by the Superintendent of Public Works before restoration of any hard surface is performed.
- A 6 bag minimum concrete mix design which achieves a 4000 psi compressive strength in 14 days is required for concrete restoration work. Mix design and supplier is to be approved by Superintendent of Public Works.
- Curb and gutter restoration work shall be 31" vertical face type conforming to Village standards.
- Pavement depth shall match existing pavement thickness.
- Superintendent of Public Works must be notified 24 hours in advance of date of concrete finishing.
- Asphalt pavement and Composite pavement restoration work requirements will vary. Contact the Village Supt. of Public Works for job specific Asphalt and/or Composite pavement restoration specifications.
- Soft Surface Excavation fee is \$50 each hole. Soft Surface Restoration must be with sod only, unless specified by DPW Superintendent – call to confirm.
- Hard Surface Excavation fee is \$200 each hole. Core holes are considered hard surfaces.
- NO PULL BOXES OR VAULTS in public walk ways.